



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.1	41			Y
2	8.2	41			Y
3	8.3	43			Y
4	8.4	41			Y
5	8.4	41			Y
6	8.7	40			Y
7	7.7	47			Y
8	7.8	39			Y
9	8.1	37			Y
10	off	off			
11	8.0	47			Y
12	8.0	44			Y
13	8.0	35			Y
14	8.0	35			Y
15	8.0	35			Y
16	off	off			
17	7.7	35			Y
18	7.7	42			Y
19	7.9	35			Y
20	7.9	37			Y
21	off	off			
22	off	off			
23	off	off			
24	off	off			
25	8.8	44			Y
26	7.9	43			Y
27	7.8	41			Y
28	8.3	42			Y
29	off	off			
30	off	off			
31	off	off			

<< Have minimums been met for this day?

<b>ENTRY POINT</b>	
PWS ID:	4   1   0   0   0   4   1
System Name:	City of Amity
Entry Point:	EP-D
Sample Period:	Mar. 26
	Month / Year

**Number of excursions\* during this month:**   
 (Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:**   
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

<b>Minimum Water Quality Parameters as set by State:</b>	
pH	7.5
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

**Print Name:** Darrel Lockard

**Signature:** *Darrel Lockard*

**Date:** 4/9/2026

(NO=N=Excursions) **Total N's**