



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1		10301 Bellavue Hwy	7.9	55			Y
2		108 stanley	7.8	52			Y
3							
4		1008 GOUCHER ST	7.9	48			Y
5							
6							
7							
8							
9		113 3RD ST.	7.8	40			Y
10		109 GETCHELL	8.0	44			Y
11		4110 AMITY RD	7.8	53			Y
12		10301 BELLEVUE HWY	7.9	56			Y
13							
14							
15							
16							
17		108 STANLEY ST	8.0	44			Y
18		1008 GOUCHER ST	8.1	58			Y
19		313 SHERMAN ST	8.0	54			Y
20							
21							
22		514 NURSERY	8.2	46			Y
23		607 STANLEY CT	7.6	60			Y
24		205 4TH ST	8.3	34			Y
25		808 OAK ST.	8.3	40			Y
26		113 3RD.	8.0	44			Y
27							
28							
29		109 GETCHELL	7.9	52			Y
30		4110 AMITY RD	8.0	52			Y
31		10301 BELLEVUE HWY	8.6	34			Y

< Has sample met the minimum(s)?

County: Yamhill Agency: REGION 1

**Distribution**

PWS ID: 

4	1	0	0	0	4	1
---	---	---	---	---	---	---

**System Name:** City of Amity  
**Sample Period:**

Mar-21
--------

  
 Month / Year  
**Sample Frequency:** Every 36 months  
**Distribution Samples Required:** 2

**Number of excursions\* during this month:**

0
---

  
 (Count the number of days when any WQP was less then the minimum required)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 

7.5
-----

  
 Alk 

30
----

 (Alkalinity)  
 PO4 

--

 (Orthophosphate)  
 Sili 

--

 (Silicate)

**Print Name:** Richard A. Howard Sr.

**Signature:**

**Date:** Sunday, April 4, 2021

(NO=N=Excursions) **Total N's**

0
---

Send to DHS within 10 days after end of sampling period  
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381