



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1		1008 GOUCHER	8.2	40			Y
2		303 SHERMAN	8.5	38			Y
3							
4							
5		510 NURSERY	8.2	38			Y
6		607 STANLEY CT	8.7	46			Y
7							
8		205 E 4TH ST	8.5	42			Y
9							
10							
11							
12							
13							
14		808 OAK ST.	7.8	40			Y
15		113 E 3RD ST	7.6	40			Y
16							
17							
18							
19		4110 AMITY RD	7.9	48			Y
20		30103 BELLEVUE	7.6	48			Y
21		208 STANLEY ST.	7.7	48			Y
22		1008 GOUCHER	7.9	40			Y
23							
24							
25							
26		303 SHERMAN	7.8	50			Y
27		514 NURSERY	7.9	48			Y
28		607 STANLEY CT	7.8	46			Y
29							
30							

< Has sample met the minimum(s)?

County: Yamhill Agency: REGION 1

**Distribution**

PWS ID: 

4	1	0	0	0	4	1
---	---	---	---	---	---	---

**System Name:** City of Amity  
**Sample Period:**

Apr-21
--------

  
 Month / Year  
**Sample Frequency:** Every 36 months  
**Distribution Samples Required:** 2

**Number of excursions\* during this month:**

1
---

  
 (Count the number of days when any WQP was less then the minimum required)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 

7.5
-----

  
 Alk 

30
----

 (Alkalinity)  
 PO4 

--

 (Orthophosphate)  
 Sili 

--

 (Silicate)

**Print Name:** Richard A. Howard Sr.

**Signature:**

**Date:** Tuesday, May 4, 2021

(NO=N=Excursions) **Total N's**

0
---