



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1							
2							
3							
4		514 NURSERY	7.8	40			Y
5		205 4TH ST	7.5	42			Y
6		808 OAK	8.5	54			Y
7							
8							
9							
10		607 STANLEY CT	8.8	54			Y
11							
12							
13							
14							
15							
16							
17		205 4TH ST	7.8	42			Y
18		808 OAK.	7.8	44			Y
19		303 SHERMAN	7.8	40			Y
20		514 NURSERY ST	7.5	42			Y
21		607 STANLEY CRT.	8.2	46			Y
22							
23							
24		205 4TH ST.	7.8	40			Y
25		808 OAK	7.9	44			Y
26		113 E 3RD	7.8	42			Y
27		109 GETCHELL	7.7	44			Y
28		4110 AITY RD	7.8	41			Y
29							
30							
31							

< Has sample met the minimum(s)?

County: Yamhill Agency: REGION 1

**Distribution**

PWS ID: 

4	1	0	0	0	4	1
---	---	---	---	---	---	---

**System Name:** City of Amity  
**Sample Period:**

May-21
--------

  
 Month / Year  
**Sample Frequency:** Every 36 months  
**Distribution Samples Required:** 2

**Number of excursions\* during this month:**

0
---

(Count the number of days when any WQP was less then the minimum required)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

**Print Name:** Richard A. Howard Sr.

**Signature:**

**Date:** Thursday, June 3, 2021

(NO=N=Excursions) **Total N's**

0
---

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381