



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1							
2							
3							
4							
5							
6							
7							
8		607 STANLEY CRT.	7.8	45			Y
9		205 4TH ST.	8.0	50			Y
10							
11							
12		113 E. 3RD	7.7	45			Y
13		808 OAK	8.2	44			Y
14		607 STANLEY CRT.	8.2	44			Y
15		205 4TH ST	8.2	46			Y
16		808 OAK	8.1	42			Y
17							
18							
19							
20		4110 AMITY RD	7.9	44			Y
21		10301 BELLEVUE HWY	8.2	46			Y
22		108 STANLEY ST	7.9	46			Y
23							
24							
25							
26		1008 GOUCHER ST	8.3	40			Y
27							
28		303 SHERMEN	7.8	50			Y
29		514 NURSERY	8.2	48			Y
30		607 STANLEY CRT	8.2	50			Y
31							

< Has sample met the minimum(s)?

County: Yamhill Agency: REGION 1

**Distribution**

PWS ID: 

4	1	0	0	0	4	1
---	---	---	---	---	---	---

**System Name:** City of Amity

**Sample Period:**

Jul-21
--------

  
Month / Year

**Sample Frequency:** Every 36 months

**Distribution Samples Required:** 2

**Number of excursions\* during this month:**

0
---

  
 (Count the number of days when any WQP was less then the minimum required)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 

7.5
-----

Alk 

30
----

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Sili 

--

 (Silicate)

**Print Name:** Richard A. Howard Sr.

**Signature:**

**Date:** Tuesday, August 3, 2021

(NO=N=Excursions) **Total N's**

0
---