



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1		205 4TH ST	8.1	40			Y
2							
3							
4							
5							
6							
7							
8		808 OAK ST	8.4	40			Y
9		113 3RD ST	8.2	42			Y
10		109 GETCHELL ST	8.3	45			Y
11							
12							
13		10301 BELLEVUE HWY	8.6	54			Y
14							
15							
16							
17		113 3RD	8.4	60			Y
18							
19							
20							
21							
22							
23							
24							
25							
26							
27		109 GETCHELL ST	8.1	52			Y
28		4110 NURSERY	8.0	48			Y
29							
30							

< Has sample met the minimum(s)?

County: Yamhill Agency: REGION 1

Distribution

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
Sample Period:

Sep-21

 Month / Year
Sample Frequency: Every 36 months
Distribution Samples Required: 2

Number of excursions* during this month:

0

(Count the number of days when any WQP was less then the minimum required)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

7.5

 Alk

30

 (Alkalinity)
 PO4

--

 (Orthophosphate)
 Sili

--

 (Silicate)

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Tuesday, October 5, 2021

(NO=N=Excursions) **Total N's**

0
