



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1		108 STANLEY	7.9	48			Y
2		1008 GOUCHER	7.9	44			Y
3		303 SHERMAN ST	8.0	37			Y
4							
5							
6							
7		514 NURSERY ST	7.7	54			Y
8							
9		607 STANLEY CT	7.8	42			Y
10							
11							
12							
13							
14							
15		205 4TH ST	7.8	54			Y
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

< Has sample met the minimum(s)?

County: Yamhill Agency: REGION 1

**Distribution**

PWS ID: 

4	1	0	0	0	4	1
---	---	---	---	---	---	---

**System Name:** City of Amity

**Sample Period:**

Dec-21
--------

  
Month / Year

**Sample Frequency:** Every 36 months

**Distribution Samples Required:** 2

**Number of excursions\* during this month:**

1
---

(Count the number of days when any WQP was less then the minimum required)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 

7.5
-----

Alk 

30
----

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Sili 

--

 (Silicate)

**Print Name:** Richard A. Howard Sr.

**Signature:**

**Date:** Thursday, January 7, 2021

(NO=N=Excursions) **Total N's**

0
---

Send to DHS within 10 days after end of sampling period  
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381