



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11		113 3RD STREET	7.5	54			Y
12							
13		109 GETCHELL	7.5	56			Y
14		113 3RD ST	8.1	53			Y
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

< Has sample met the minimum(s)?

County: Yamhill Agency: REGION 1

**Distribution**

PWS ID: 

4	1	0	0	0	4	1
---	---	---	---	---	---	---

**System Name:** City of Amity  
**Sample Period:** Jan-22  
 Month / Year  
**Sample Frequency:** Every 36 months  
**Distribution Samples Required:** 2

**Number of excursions\* during this month:**

0
---

(Count the number of days when any WQP was less then the minimum required)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 

7.5
-----

  
 Alk 

30
----

 (Alkalinity)  
 PO4 

--

 (Orthophosphate)  
 Sili 

--

 (Silicate)

**Print Name:** Richard A. Howard Sr.

**Signature:** *Richard A. Howard Sr.*

**Date:** Monday, February 7, 2022

(NO=N=Excursions) **Total N's**

0
---

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381