

Day	pH	Alk	Phos	Other	Y/N
1	7.81				Y
2	7.80				Y
3	7.83				Y
4	7.82				Y
5	7.96				Y
6	7.99				Y
7	8.31				Y
8	8.27				Y
9	8.27				Y
10	8.36				Y
11	8.36				Y
12	8.19				Y
13	8.20				Y
14	8.38				Y
15	8.42				Y
16	8.36				Y
17	8.52				Y
18	8.36				Y
19	8.31				Y
20	8.26				Y
21	8.69				Y
22	8.64				Y
23	8.69				Y
24	8.36				Y
25	8.36				Y
26	8.48				Y
27	8.65				Y
28	8.60				Y
29					
30					
31					
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: February 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

 (Alkalinity)

PO4

--


 (Orthophosphate)

Other

--

 (_____)

Print Name: Dan Waterbury

Signature: 

Date: 3/08/2021

Send to DWP within 10 days after end of sampling period