

Day	pH	Alk	Phos	Other	Y/N
1	8.62				Y
2	8.63				Y
3	8.58				Y
4	8.61				Y
5	8.63				Y
6	7.42				Y
7	8.66				Y
8	8.57				Y
9	8.39				Y
10	8.78				Y
11	8.78				Y
12	8.69				Y
13	7.57				Y
14	7.76				Y
15	7.77				Y
16	7.60				Y
17	7.54				Y
18	7.34				Y
19	7.50				Y
20	7.83				Y
21	7.71				Y
22	7.71				Y
23	7.67				Y
24	7.74				Y
25	7.72				Y
26	7.73				Y
27	7.86				Y
28	7.95				Y
29	7.91				Y
30	7.92				Y
31	8.14				Y
					0

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: March 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature:

Date: 4/08/2021

Send to DWP within 10 days after end of sampling period