

Day	pH	Alk	Phos	Other	Y/N
1	8.63				Y
2	8.26				Y
3	8.22				Y
4	8.04				Y
5	7.96				Y
6	7.99				Y
7	7.78				Y
8	8.04				Y
9	8.18				Y
10	8.21				Y
11	8.27				Y
12	8.41				Y
13	7.92				Y
14	7.87				Y
15	7.92				Y
16	7.88				Y
17	8.33				Y
18	8.26				Y
19	7.74				Y
20	7.90				Y
21	7.73				Y
22	7.83				Y
23	7.72				Y
24	7.71				Y
25	7.79				Y
26	7.78				Y
27	7.89				Y
28	7.68				Y
29	7.74				Y
30	7.72				Y
31					Y
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: June 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 7/08/2021

Send to DWP within 10 days after end of sampling period