

Day	pH	Alk	Phos	Other	Y/N
1	8.18				Y
2	8.07				Y
3	8.19				Y
4	8.25				Y
5	8.43				Y
6	8.36				Y
7	8.34				Y
8	8.40				Y
9	8.43				Y
10	8.42				Y
11	8.59				Y
12	8.44				Y
13	8.50				Y
14	8.44				Y
15	8.43				Y
16	8.41				Y
17	8.50				Y
18	8.55				Y
19	8.74				Y
20	8.77				Y
21	8.26				Y
22	8.04				Y
23	7.98				Y
24	8.14				Y
25	8.02				Y
26	7.92				Y
27	7.91				Y
28	7.80				Y
29	7.96				Y
30	7.89				Y
31					
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: September 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

()

Print Name: Dan Waterbury

Signature: 

Date: 10/05/2021

Send to DWP within 10 days after end of sampling period