

Day	pH	Alk	Phos	Other	Y/N
1	8.37				Y
2	7.91				Y
3	7.90				Y
4	7.71				Y
5	7.58				Y
6	7.52				Y
7	7.63				Y
8	7.64				Y
9	7.79				Y
10	7.83				Y
11	7.92				Y
12	7.96				Y
13	7.99				Y
14	8.17				Y
15	8.57				Y
16	8.26				Y
17	7.98				Y
18	8.16				Y
19	8.31				Y
20	8.32				Y
21	8.32				Y
22	8.34				Y
23	8.27				Y
24	8.32				Y
25	8.73				Y
26	8.48				Y
27	8.21				Y
28	8.13				Y
29	7.98				Y
30	8.77				Y
31					
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: November 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 12/08/2021

Send to DWP within 10 days after end of sampling period