

Day	pH	Alk	Phos	Other	Y/N
1	7.88				Y
2	7.85				Y
3	7.89				Y
4	7.96				Y
5	8.01				Y
6	8.17				Y
7	8.39				Y
8	8.59				Y
9	8.53				Y
10	8.91				Y
11	8.57				Y
12	8.40				Y
13	8.37				Y
14	8.38				Y
15	8.25				Y
16	7.91				Y
17	8.04				Y
18	8.63				Y
19	8.71				Y
20	8.64				Y
21	7.79				Y
22	7.91				Y
23	7.98				Y
24	7.95				Y
25	8.65				Y
26	7.93				Y
27	8.78				Y
28	8.61				Y
29	7.59				Y
30	7.76				Y
31	7.88				Y
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: January 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 2/07/2022

Send to DWP within 10 days after end of sampling period