

Day	pH	Alk	Phos	Other	Y/N
1	8.48				Y
2	8.27				Y
3	8.28				Y
4	8.25				Y
5	8.40				Y
6	8.56				Y
7	8.61				Y
8	8.71				Y
9	8.64				Y
10	8.67				Y
11	8.64				Y
12	8.72				Y
13	8.58				Y
14	8.59				Y
15	8.87	45.0			Y
16	8.88				Y
17	9.09				Y
18	8.70				Y
19	8.93				Y
20	9.06				Y
21	8.70				Y
22	9.00				Y
23	8.96				Y
24	9.00				Y
25	8.63				Y
26	8.86				Y
27	8.41				Y
28	8.86				Y
29	8.45				Y
30	8.89	45.0			Y
31					Y
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: April 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)



For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature:

Date: 5/10/2022

Send to DWP within 10 days after end of sampling period