

Day	pH	Alk	Phos	Other	Y/N
1	8.40	45.0			
2	8.80				
3	8.48				
4	8.47				
5	8.50				
6	8.70				
7	8.68				
8	8.99				
9	8.69				
10	8.93				
11	9.14				
12	8.39				
13	9.04				
14	8.68	45.0			
15	8.38				
16	8.97				
17	9.04				
18	8.87				
19	8.54				
20	8.34				
21	8.71				
22	8.60				
23	8.38				
24	8.40				
25	8.36				
26	8.38				
27	8.45				
28	8.35	45.0			
29	8.26				
30	8.19				
31	8.09				
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: May 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature:

Date: 6/3/2022

Send to DWP within 10 days after end of sampling period