

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.14				
2	8.08				
3	8.16				
4	8.31				
5	8.36				
6	7.84				
7	8.08				
8	8.29				
9	8.19				
10	8.37				
11	8.28				
12	8.18	45.0			
13	8.18				
14	8.31				
15	8.02				
16	8.29				
17	8.39				
18	8.25				
19	8.31				
20	8.34				
21	8.35				
22	8.52				
23	8.26				
24	8.29				
25	8.41				
26	8.34	45.0			
27	8.31				
28	8.42				
29	8.40				
30	8.23				
31					
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: June 2022

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

 Alk

30.0

 (Alkalinity)
 PO4

--

 (Orthophosphate)
 Other

--

 (_____)

Print Name: Dan Waterbury

Signature: 

Date: 7/8/2022

Send to DWP within 10 days after end of sampling period