

Day	pH	Alk	Phos	Other	Y/N
1	8.50				
2	8.39				
3	8.60				
4	8.22				
5	8.24				
6	8.32				
7	8.31				
8	8.49	45.0			
9	8.13				
10	8.04				
11	7.90				
12	8.00				
13	7.92				
14	7.90				
15	7.88				
16	7.86				
17	8.03				
18	7.77				
19	7.84				
20	7.80	45.0			
21	7.81				
22	8.24				
23	7.83				
24	7.76				
25	7.88				
26	7.88				
27	7.92				
28	7.94				
29	8.02				
30	8.17				
31	8.21				

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: July 2022  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature: 

Date: 8/8/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 

0
---