

Day	pH	Alk	Phos	Other	Y/N
1	8.04				Y
2	8.03				Y
3	8.07				Y
4	8.00				Y
5	7.95				Y
6	8.02				Y
7	8.02				Y
8	8.08	40.0			Y
9	8.18				Y
10	8.21				Y
11	8.23				Y
12	8.13				Y
13	8.17				Y
14	8.07				Y
15	8.13				Y
16	8.28				Y
17	8.26				Y
18	7.94				Y
19	8.22				Y
20	8.13				Y
21	8.18				Y
22	8.11	45.0			Y
23	8.16				Y
24	8.30				Y
25	8.21				Y
26	8.18				Y
27	8.03				Y
28	8.25				Y
29	8.27				Y
30	8.24				Y
31					
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: September 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 10/10/2022

Send to DWP within 10 days after end of sampling period