

Day	pH	Alk	Phos	Other	Y/N
1	8.12	45.0			
2	8.05				
3	8.22				
4	8.15				
5	8.22				
6	7.94				
7	7.94				
8	7.99				
9	8.01				
10	8.05				
11	8.08				
12	8.10				
13	8.12	45.0			
14	8.02				
15	8.05				
16	8.09				
17	8.09				
18	8.27				
19	8.46				
20	8.29				
21	8.48				
22	8.52				
23	8.56				
24	8.52				
25	8.50	45.0			
26	8.33				
27	8.48				
28	8.77				
29	8.30				
30	8.20				
31	8.20				
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: October 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 11/8/2022

Send to DWP within 10 days after end of sampling period