

Day	pH	Alk	Phos	Other	Y/N
1	8.24				
2	8.19				
3	8.56				
4	8.45				
5	8.37				
6	8.68				
7	8.95	45.0			
8	9.19				
9	9.19				
10	9.15				
11	8.98				
12	8.83				
13	8.79				
14	8.93				
15	8.73				
16	8.37				
17	8.02				
18	7.96				
19	8.03	45.0			
20	8.07				
21	7.91				
22	7.93				
23	7.81				
24	7.81				
25	7.81				
26	7.80				
27	7.84				
28	7.76				
29	7.81				
30	8.03				
31					
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: BA

Sample Period: November 2022  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

*(Alkalinity)*

PO4 

--

*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature:

Date: 12/8/2022

Send to DWP within 10 days after end of sampling period