

Day	pH	Alk	Phos	Other	Y/N
1	7.95				
2	8.79				
3	8.81				
4	8.52				
5	8.30				
6	8.58	45.0			
7	8.47				
8	8.41				
9	8.28				
10	8.14				
11	8.02				
12	8.03				
13	8.02				
14	8.01				
15	7.98				
16	7.88				
17	7.96				
18	8.02	45.0			
19	7.82				
20	7.90				
21	7.94				
22	7.92				
23	7.81				
24	7.86				
25	7.92				
26	7.91				
27	7.91				
28	7.83				
29	8.00				
30	8.22	45.0			
31	8.21				
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

### ENTRY POINT

**PWS ID: 41**

0	0	0	6	3
---	---	---	---	---

**System Name:** Wickiup Water District

**Entry Point:** A

**Sample Period:** October 2022

*Month/Year*

**Number of excursions\* during this month: 0**  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0**  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

#### Minimum Water Quality Parameters as set by

pH 

7.2
-----

Alk 

30.0
------

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Other 

--

 (\_\_\_\_\_)

**Print Name:** Dan Waterbury

**Signature:**

**Date:** 1/7/2023

Send to DWP within 10 days after end of sampling period