

Day	pH	Alk	Phos	Other	Y/N
1	8.12				
2	8.02				
3	7.78				
4	7.80				
5	7.56				
6	7.54	45.0			
7	7.70				
8	7.80				
9	7.82				
10	8.05				
11	7.67				
12	8.24				
13	7.62				
14	7.64				
15	7.69				
16	8.20				
17	7.93				
18	7.99	45.0			
19	7.94				
20	8.39				
21	8.03				
22	8.39				
23	8.28				
24	8.46				
25	8.32				
26	8.28				
27	8.10				
28	8.13				
29	8.01				
30	7.86	45.0			
31	7.76				
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: January 2023  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature: 

Date: 2/7/2023

Send to DWP within 10 days after end of sampling period