

Day	pH	Alk	Phos	Other	Y/N
1	7.90				Y
2	7.78				Y
3	7.85				Y
4	7.76				Y
5	7.86				Y
6	7.79				Y
7	8.05				Y
8	8.02				Y
9	8.04				Y
10	8.01				Y
11	8.12	45.0			Y
12	8.13				Y
13	7.94				Y
14	8.02				Y
15	7.88				Y
16	8.19				Y
17	8.20				Y
18	8.18				Y
19	8.07				Y
20	8.16				Y
21	7.75				Y
22	8.12				Y
23	8.12	45.0			Y
24	8.05				Y
25	8.12				Y
26	8.18				Y
27	8.17				Y
28	7.82				Y
29					
30					
31					
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: February 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 3/07/2023

Send to DWP within 10 days after end of sampling period