

Day	pH	Alk	Phos	Other	Y/N
1	8.03				
2	8.34				
3	8.35				
4	8.01				
5	8.03				
6	8.17				
7	8.03	45.0			
8	8.02				
9	8.03				
10	8.41				
11	8.20				
12	8.21				
13	7.93				
14	8.15				
15	8.01				
16	8.10				
17	8.29				
18	8.32				
19	8.21	45.0			
20	8.24				
21	8.45				
22	8.46				
23	8.15				
24	8.30				
25	8.15				
26	8.14				
27	8.24				
28	8.27				
29	8.48				
30	8.32				
31	8.24	45.0			
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: March 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 4/4/2023

Send to DWP within 10 days after end of sampling period