

Day	pH	Alk	Phos	Other	Y/N
1	8.25				
2	8.13				
3	8.18				
4	8.17				
5	8.21				
6	8.16				
7	8.23				
8	8.21				
9	8.18				
10	8.12				
11	8.01				
12	8.13	45.0			
13	8.10				
14	8.10				
15	8.20				
16	8.51				
17	8.40				
18	8.43				
19	8.19				
20	8.03				
21	8.05				
22	7.31				
23	8.25				
24	7.95	45.0			
25	8.02				
26	8.32				
27	7.91				
28	8.32				
29	7.98				
30	7.82				
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: April 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 5/5/2023

Send to DWP within 10 days after end of sampling period