

Day	pH	Alk	Phos	Other	Y/N
1	7.84				
2	7.86				
3	8.06				
4	7.79				
5	7.75				
6	7.86				
7	7.79				
8	7.75				
9	8.04				
10	7.84				
11	8.16	45.0			
12	7.72				
13	7.76				
14	7.74				
15	7.76				
16	7.77				
17	7.78				
18	7.83				
19	7.90				
20	7.93				
21	8.09				
22	8.03				
23	8.06	45.0			
24	8.06				
25	8.18				
26	8.16				
27	7.95				
28	8.06				
29	8.06				
30	8.12				
31	8.17				
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: January 2023

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

 Alk

30.0

 (Alkalinity)
 PO4

--

 (Orthophosphate)
 Other

--

 (_____)

Print Name: Dan Waterbury

Signature: 

Date: 6/5/2023

Send to DWP within 10 days after end of sampling period