

Day	pH	Alk	Phos	Other	Y/N
1	8.32				
2	8.36				
3	8.27				
4	8.54				
5	8.39				
6	8.43				
7	8.37				
8	8.35				
9	8.36				
10	8.40				
11	8.39	45.0			
12	8.52				
13	8.43				
14	8.50				
15	8.68				
16	8.57				
17	8.58				
18	8.58				
19	8.55				
20	8.46				
21	8.28				
22	8.31				
23	8.12	45.0			
24	8.12				
25	7.98				
26	8.01				
27	8.21				
28	8.39				
29	8.58				
30	8.41				
31	8.61				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: July 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

()

Print Name: Dan Waterbury

Signature: 

Date: 8/9/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0
