

Day	pH	Alk	Phos	Other	Y/N
1	8.29				
2	8.20				
3	8.33				
4	8.20				
5	8.30				
6	8.28				
7	7.93				
8	7.76				
9	8.12				
10	8.23	45.0			
11	8.27				
12	8.33				
13	8.28				
14	8.36				
15	8.11				
16	8.30				
17	8.26				
18	8.25				
19	8.14				
20	8.08				
21	8.15				
22	8.21	45.0			
23	8.21				
24	8.33				
25	8.39				
26	8.34				
27	8.37				
28	8.13				
29	8.71				
30	8.65				
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: September 2023  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature: 

Date: 10/9/2023

Send to DWP within 10 days after end of sampling period