

Day	pH	Alk	Phos	Other	Y/N
1	8.58				
2	8.68	40.0			
3	8.68				
4	8.85				
5	8.86				
6	8.62				
7	8.49				
8	8.62				
9	8.46				
10	8.55				
11	8.52				
12	8.48				
13	8.39				
14	8.41	40.0			
15	8.23				
16	8.24				
17	8.21				
18	8.42				
19	8.35				
20	8.40				
21	8.48				
22	8.52				
23	8.47				
24	8.24				
25	8.15				
26	8.24	40.0			
27	8.21				
28	8.64				
29	8.32				
30	8.45				
31	8.37				
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: October 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 11/06/2023

Send to DWP within 10 days after end of sampling period