

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.48				
2	8.44				
3	8.42				
4	8.36				
5	8.43				
6	8.83				
7	9.01				
8	9.11	40.0			
9	9.23				
10	9.27				
11	8.86				
12	9.24				
13	9.19				
14	9.00				
15	8.94				
16	8.90				
17	8.75				
18	8.77				
19	8.73				
20	8.64	40.0			
21	8.53				
22	8.41				
23	8.20				
24	8.35				
25	8.04				
26	8.14				
27	8.21				
28	7.99				
29	8.13				
30	8.19				
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: November 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

 (Alkalinity)

PO4

--

 (Orthophosphate)

Other

--

 (_____)

Print Name: Dan Waterbury

Signature:

Date: 12/7/2023

Send to DWP within 10 days after end of sampling period