

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.24	45.0			
2	8.06				
3	7.85				
4	7.66				
5	7.66				
6	7.74				
7	7.60				
8	7.93				
9	7.85				
10	7.63				
11	7.95				
12	7.92	45.0			
13	8.02				
14	7.95				
15	8.07				
16	8.03				
17	8.04				
18	7.98				
19	8.14				
20	8.15				
21	8.14				
22	7.95				
23	8.09				
24	8.16	45.0			
25	8.12				
26	8.05				
27	8.12				
28	8.00				
29	8.30				
30	8.26				
31	8.31				
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

**System Name:** Wickiup Water District

**Entry Point:** A

**Sample Period:** December 2023  
*Month/Year*

**Number of excursions\* during this month: 0**  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months: 0**  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

*(Alkalinity)*

PO4 

--

*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

**Print Name:** Dan Waterbury

**Signature:**

**Date:** 1/8/2024

Send to DWP within 10 days after end of sampling period