

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.28				Y
2	8.26				Y
3	8.23				Y
4	8.32				Y
5	8.36	45.0			Y
6	8.10				Y
7	8.03				Y
8	8.01				Y
9	8.19				Y
10	8.07				Y
11	8.12				Y
12	8.20				Y
13	8.14				Y
14	8.16				Y
15	8.05				Y
16	8.05				Y
17	8.25	45.0			Y
18	8.34				Y
19	7.91				Y
20	7.94				Y
21	7.98				Y
22	7.99				Y
23	7.96				Y
24	7.97				Y
25	8.01				Y
26	7.99				Y
27	7.93				Y
28	8.05				Y
29	8.01	45.0			Y
30	8.08				Y
31	8.06				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: January 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

 (Alkalinity)

PO4

--

 (Orthophosphate)

Other

--

 ()

Print Name: Dan Waterbury

Signature:

Date: 2/07/2024

Send to DWP within 10 days after end of sampling period