

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|--------------------------------|------|------|------|-------|-----|
| 1 | 8.10 | | | | Y |
| 2 | 8.06 | | | | Y |
| 3 | 7.98 | | | | Y |
| 4 | 7.94 | | | | Y |
| 5 | 7.92 | | | | Y |
| 6 | 7.86 | | | | Y |
| 7 | 8.04 | | | | Y |
| 8 | 8.04 | | | | Y |
| 9 | 8.14 | | | | Y |
| 10 | 8.12 | 45.0 | | | Y |
| 11 | 8.10 | | | | Y |
| 12 | 8.02 | | | | Y |
| 13 | 8.05 | | | | Y |
| 14 | 8.24 | | | | Y |
| 15 | 8.07 | | | | Y |
| 16 | 8.23 | | | | Y |
| 17 | 8.05 | | | | Y |
| 18 | 7.99 | | | | Y |
| 19 | 7.96 | | | | Y |
| 20 | 7.94 | | | | Y |
| 21 | 8.44 | | | | Y |
| 22 | 8.04 | 45.0 | | | Y |
| 23 | 8.36 | | | | Y |
| 24 | 8.32 | | | | Y |
| 25 | 8.48 | | | | Y |
| 26 | 8.35 | | | | Y |
| 27 | 8.32 | | | | Y |
| 28 | 8.43 | | | | Y |
| 29 | 8.54 | | | | Y |
| 30 | | | | | Y |
| 31 | | | | | Y |
| (No = N = Excursion) Total N's | | | | | 0 |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

| | | | | |
|---|---|---|---|---|
| 0 | 0 | 0 | 6 | 3 |
|---|---|---|---|---|

System Name: Wickiup Water District

Entry Point: A

Sample Period: February 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

| |
|-----|
| 7.2 |
|-----|

Alk

| |
|------|
| 30.0 |
|------|

 (Alkalinity)

PO4

| |
|--|
| |
|--|

 (Orthophosphate)

Other

| |
|--|
| |
|--|

 (_____)

Print Name: Dan Waterbury

Signature:

Date: 3/08/2024

Send to DWP within 10 days after end of sampling period