

Day	pH	Alk	Phos	Other	Y/N
1	8.73				
2	8.69				
3	8.71				
4	8.74				
5	8.72				
6	8.66				
7	8.65	45.0			
8	8.63				
9	8.46				
10	8.23				
11	8.35				
12	8.64				
13	8.55				
14	8.51				
15	8.39				
16	8.71				
17	8.41				
18	8.22				
19	8.05	45.0			
20	8.36				
21	8.39				
22	8.05				
23	8.14				
24	8.09				
25	7.74				
26	7.73				
27	7.97				
28	7.96				
29	8.62				
30	8.13				
31	7.83	45.0			

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00063

System Name: Wickiup Water District

Entry Point: A

Sample Period: March 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 30.0 *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*

Print Name: Dan Waterbury

Signature:

Date: 4/4/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0