

Day	pH	Alk	Phos	Other	Y/N
1	7.75				
2	8.26				
3	8.24				
4	7.51				
5	8.22				
6	7.65				
7	7.68				
8	8.26				
9	7.76				
10	8.09	45.0			
11	8.13				
12	7.82				
13	8.31				
14	8.06				
15	8.19				
16	8.23				
17	8.10				
18	8.34				
19	8.38				
20	8.52				
21	8.51				
22	8.56	45.0			
23	8.56				
24	8.29				
25	8.41				
26	8.44				
27	8.55				
28	8.44				
29	8.35				
30	8.21				
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: April 2024  
*Month/Year*

**Number of excursions\* during this month: 0**  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months: 0**  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature: 

Date: 5/8/2024

Send to DWP within 10 days after end of sampling period