

Day	pH	Alk	Phos	Other	Y/N
1	8.55				
2	8.46				
3	8.51				
4	8.25				
5	8.18				
6	7.95				
7	7.93				
8	8.23				
9	8.22	45.0			
10	8.21				
11	8.26				
12	8.41				
13	8.38				
14	8.31				
15	8.49				
16	8.42				
17	8.37				
18	8.29				
19	8.24				
20	8.24				
21	8.36	45.0			
22	8.23				
23	8.31				
24	8.29				
25	8.17				
26	8.45				
27	8.05				
28	8.39				
29	7.83				
30	8.50				
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: June 2024  
*Month/Year*

**Number of excursions\* during this month: 0**  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months: 0**  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

30.0
------

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature: 

Date: 7/9/2024

Send to DWP within 10 days after end of sampling period