

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.55				
2	8.45				
3	8.36	45.0			
4	8.51				
5	8.36				
6	8.07				
7	7.92				
8	7.89				
9	8.06				
10	8.11				
11	8.04				
12	7.99				
13	8.02				
14	8.08				
15	8.13	45.0			
16	8.12				
17	8.08				
18	8.14				
19	8.13				
20	8.06				
21	8.03				
22	8.00				
23	8.05				
24	7.99				
25	8.12				
26	8.36				
27	8.36	45.0			
28	8.37				
29	7.81				
30	8.15				
31	7.95				
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 6 3

System Name: Wickiup Water District

Entry Point: A

Sample Period: July 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 30.0 *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*

Print Name: Dan Waterbury

Signature:

Date: 8/8/2024

Send to DWP within 10 days after end of sampling period