

Day	pH	Alk	Phos	Other	Y/N
1	7.78				
2	7.81				
3	7.96				
4	8.07				
5	8.11				
6	8.12				
7	8.18				
8	8.37	45.0			
9	8.28				
10	8.34				
11	8.32				
12	8.27				
13	8.24				
14	8.55				
15	8.29				
16	8.34				
17	8.41				
18	8.43				
19	8.42				
20	8.32	45.0			
21	8.17				
22	8.15				
23	8.24				
24	8.17				
25	8.39				
26	8.28				
27	8.42				
28	8.17				
29	8.15				
30	8.19				
31	8.24				

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: August 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

30.0

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 9/9/2024

Send to DWP within 10 days after end of sampling period