

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.26	45.0			
2	8.24				
3	8.19				
4	8.19				
5	8.35				
6	8.33				
7	8.29				
8	8.35				
9	8.35				
10	8.37				
11	7.58				
12	8.36				
13	8.45	45.0			
14	8.54				
15	8.52				
16	8.45				
17	8.57				
18	8.65				
19	8.57				
20	8.56				
21	8.24				
22	8.47				
23	8.52				
24	8.51				
25	8.48	45.0			
26	8.51				
27	8.52				
28	8.27				
29	8.21				
30	8.27				
31					
(No = N = Excursion) Total N's					0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: September 2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

 Alk

30.0

 (Alkalinity)
 PO4

--

 (Orthophosphate)
 Other

--

 ()

Print Name: Dan Waterbury

Signature: 

Date: 10/10/2024

Send to DWP within 10 days after end of sampling period