

Day	pH	Alk	Phos	Other	Y/N
1	8.36				
2	8.33				
3	8.55				
4	8.36				
5	8.54				
6	8.44				
7	8.60				
8	8.62				
9	8.47				
10	8.31				
11	8.72				
12	8.63				
13	8.62				
14	8.59				
15	8.63				
16	8.39				
17	8.62				
18	8.56	55			
19	8.41				
20	8.23				
21	8.06				
22	7.97				
23	8.08				
24	8.23	45			
25	8.07				
26	8.02				
27	8.20				
28	8.17				
29	8.06				
30	8.07				
31	8.31	45			

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: A

Sample Period: Oct/2024

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)



For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk 30 (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Eric Bufkin

Signature: 

Date: 11-08-24

Send to DWP within 10 days after end of
sampling period