

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.39				
2	8.63				
3	8.53				
4	8.37				
5	8.25				
6	8.39				
7	8.15	45			
8	8.13				
9	8.29				
10	7.98				
11	8.09				
12	8.21				
13	8.31				
14	7.72				
15	7.35				
16	8.24				
17	8.45				
18	8.33				
19	8.69				
20	8.50				
21	8.32	40			
22	8.24				
23	9.0				
24	8.43				
25	7.8				
26	7.70				
27	7.8				
28	7.81				
29	7.52				
30	7.68				
31					

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00063

System Name: Wickiup Water District

Entry Point: A

Sample Period: Nov 2024
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
Alk 30.0 (Alkalinity)
PO4 (Orthophosphate)
Other (_____)

Print Name: Eric Bufkin

Signature: 

Date: 12/09/2024

Send to DWP within 10 days after end of
sampling period