

Day	pH	Alk	Phos	Other	Y/N
1	7.64				Y
2	7.55				Y
3	7.54				Y
4	7.49				Y
5	7.53				Y
6	7.53				Y
7	7.79				Y
8	7.79				Y
9	7.76				Y
10	7.96				Y
11	7.82				Y
12	7.51				Y
13	7.54				Y
14	7.54				Y
15	7.89				Y
16	7.56				Y
17	8.03				Y
18	7.56				Y
19	7.63				Y
20	7.63				Y
21	7.52				Y
22	7.48				Y
23	7.61				Y
24	7.62				Y
25	7.54				Y
26	7.62				Y
27	7.56				Y
28	7.86				Y
29					
30					
31					
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: February 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

 (Alkalinity)

PO4

--


 (Orthophosphate)

Other

--

 (_____)

Print Name: Dan Waterbury

Signature: 

Date: 3/08/2021

Send to DWP within 10 days after end of sampling period