

| Day | pH | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1 | 8.17 | | | | Y |
| 2 | 8.15 | | | | Y |
| 3 | 8.38 | | | | Y |
| 4 | 8.38 | | | | Y |
| 5 | 8.27 | | | | Y |
| 6 | 8.16 | | | | Y |
| 7 | 8.32 | | | | Y |
| 8 | 8.18 | | | | Y |
| 9 | 8.14 | | | | Y |
| 10 | 8.07 | | | | Y |
| 11 | 8.06 | | | | Y |
| 12 | 8.18 | | | | Y |
| 13 | 8.05 | | | | Y |
| 14 | 8.24 | | | | Y |
| 15 | 8.07 | | | | Y |
| 16 | 8.09 | | | | Y |
| 17 | 8.02 | | | | Y |
| 18 | 7.82 | | | | Y |
| 19 | 7.92 | | | | Y |
| 20 | 7.89 | | | | Y |
| 21 | 8.16 | | | | Y |
| 22 | 8.32 | | | | Y |
| 23 | 8.52 | | | | Y |
| 24 | 8.59 | | | | Y |
| 25 | 8.70 | | | | Y |
| 26 | 8.72 | | | | Y |
| 27 | 8.66 | | | | Y |
| 28 | 8.90 | | | | Y |
| 29 | 8.88 | | | | Y |
| 30 | 8.89 | | | | Y |
| 31 | | | | | Y |
| | | | | | 0 |

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

| | | | | |
|---|---|---|---|---|
| 0 | 0 | 0 | 6 | 3 |
|---|---|---|---|---|

System Name: Wickiup Water District

Entry Point: B

Sample Period: April 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

| |
|-----|
| 7.2 |
|-----|

Alk

| |
|--|
| |
|--|

 (Alkalinity)

PO4

| |
|--|
| |
|--|


 (Orthophosphate)

Other

| |
|--|
| |
|--|

 (_____)

Print Name: Dan Waterbury

Signature: 

Date: 5/03/2021

Send to DWP within 10 days after end of sampling period