

Day	pH	Alk	Phos	Other	Y/N
1	8.69				Y
2	8.63				Y
3	8.68				Y
4	8.79				Y
5	8.76				Y
6	8.83				Y
7	8.73				Y
8	8.65				Y
9	8.62				Y
10	8.73				Y
11	8.67				Y
12	8.72				Y
13	8.63				Y
14	8.62				Y
15	8.63				Y
16	8.70				Y
17	8.68				Y
18	8.64				Y
19	8.69				Y
20	8.67				Y
21	8.65				Y
22	8.62				Y
23	8.67				Y
24	8.72				Y
25	8.64				Y
26	8.67				Y
27	8.70				Y
28	8.67				Y
29	8.63				Y
30	8.60				Y
31	8.58				Y
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: May 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

(Alkalinity)

PO4

--


(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature: 

Date: 6/08/2021

Send to DWP within 10 days after end of sampling period