

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.63				Y
2	8.44				Y
3	8.30				Y
4	8.33				Y
5	8.12				Y
6	8.33				Y
7	8.31				Y
8	8.21				Y
9	8.25				Y
10	8.15				Y
11	8.14				Y
12	8.37				Y
13	8.29				Y
14	8.20				Y
15	8.22				Y
16	8.19				Y
17	8.07				Y
18	7.94				Y
19	7.90				Y
20	7.82				Y
21	7.76				Y
22	7.73				Y
23	8.19				Y
24	8.36				Y
25	8.05				Y
26	7.90				Y
27	7.81				Y
28	7.64				Y
29	7.61				Y
30	7.77				Y
31					Y
					0

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: June 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Dan Waterbury

Signature:

Date: 7/08/2021

Send to DWP within 10 days after end of sampling period