

Day	pH	Alk	Phos	Other	Y/N
1	7.75				Y
2	7.77				Y
3	7.73				Y
4	7.74				Y
5	7.78				Y
6	7.86				Y
7	7.81				Y
8	7.73				Y
9	7.71				Y
10	7.72				Y
11	7.74				Y
12	7.66				Y
13	7.70				Y
14	7.68				Y
15	7.64				Y
16	7.69				Y
17	7.63				Y
18	7.80				Y
19	7.67				Y
20	7.76				Y
21	7.77				Y
22	7.75				Y
23	7.84				Y
24	7.64				Y
25	7.59				Y
26	7.53				Y
27	7.45				Y
28	7.49				Y
29	7.48				Y
30	7.42				Y
31	7.41				Y
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: July 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

 (Alkalinity)

PO4

--


 (Orthophosphate)

Other

--

 ()

Print Name: Dan Waterbury

Signature: 

Date: 8/06/2021

Send to DWP within 10 days after end of sampling period