

Day	pH	Alk	Phos	Other	Y/N
1	7.88				Y
2	7.87				Y
3	7.94				Y
4	8.06				Y
5	8.13				Y
6	8.21				Y
7	8.13				Y
8	8.13				Y
9	8.31				Y
10	8.38				Y
11	8.46				Y
12	8.45				Y
13	8.44				Y
14	8.37				Y
15	8.30				Y
16	8.20				Y
17	8.15				Y
18	8.07				Y
19	8.09				Y
20	8.35				Y
21	8.47				Y
22	7.58				Y
23	7.65				Y
24	7.69				Y
25	7.88				Y
26	8.02				Y
27	8.11				Y
28	8.15				Y
29	8.26				Y
30	8.15				Y
31					
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

**System Name:** Wickiup Water District

**Entry Point:** B

**Sample Period:** September 2021  
*Month/Year*

**Number of excursions\* during this month: 0**  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months: 0**  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

--

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

**Print Name:** Dan Waterbury

**Signature:** 

**Date:** 10/05/2021

Send to DWP within 10 days after end of sampling period