

Day	pH	Alk	Phos	Other	Y/N
1	8.71				Y
2	8.81				Y
3	8.58				Y
4	8.20				Y
5	8.09				Y
6	7.72				Y
7	7.77				Y
8	7.75				Y
9	7.62				Y
10	7.71				Y
11	7.64				Y
12	7.63				Y
13	7.65				Y
14	7.82				Y
15	8.13				Y
16	8.43				Y
17	8.48				Y
18	8.67				Y
19	8.55				Y
20	8.78				Y
21	8.95				Y
22	8.96				Y
23	8.73				Y
24	8.37				Y
25	8.62				Y
26	8.62				Y
27	8.48				Y
28	8.66				Y
29	8.68				Y
30	8.63				Y
31					
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: November 2021  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

--

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature: 

Date: 12/08/2021

Send to DWP within 10 days after end of sampling period