

Day	pH	Alk	Phos	Other	Y/N
1	8.58				Y
2	8.61				Y
3	8.56				Y
4	8.55				Y
5	8.29				Y
6	8.32				Y
7	8.38				Y
8	8.55				Y
9	8.58				Y
10	8.33				Y
11	8.30				Y
12	8.43				Y
13	8.48				Y
14	8.57				Y
15	8.52				Y
16	8.64				Y
17	8.59				Y
18	8.66				Y
19	8.61				Y
20	8.52				Y
21	8.58				Y
22	8.73				Y
23	8.69				Y
24	8.66				Y
25	8.63				Y
26	8.69				Y
27	8.70				Y
28	8.77				Y
29	8.47				Y
30	8.53				Y
31	8.51				Y
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	6	3
---	---	---	---	---

System Name: Wickiup Water District

Entry Point: B

Sample Period: January 2022  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

Alk 

--

*(Alkalinity)*

PO4 

--


*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Dan Waterbury

Signature: 

Date: 2/07/2022

Send to DWP within 10 days after end of sampling period